Minimum fall 5° (inc roof) to allow water to run off
Maximum fall 15° (inc roof)

IF INCLUDING BLACKOUT BLINDS

When blinds are selected, plaster up to blind trim

Black out blind option

When no blind is selected, distance between plaster stop bead and glass to be approx 10mm and must not be in contact with glass

Do not lift by the glass

Lift from here (dedicated drip overhang)

Roof membrane tucked and sealed under dedicated drip lip. If using torch on felt, cut to size, fold back and pre-heat before applying to the upstand and profile - DO NOT APPLY HEAT TO THE ROOFLIGHT

Pre-drill frame and screw fix through purpose made recess as per your step by step fitting guide

Stop bead

Silicone bead to be applied all the way around your upstand before lowering your rooflight into place

75mm width timber upstand, minimum height of 25mm.

Arris Rail (Recomended)

EPDM roof finish, for alternative finishes, please refer to your step by step installaton guide

Plasterboard

Plywood Deck

Internal sizes
taken from here
(size ordered = size of timber structural opening)

ROOF MAKER
WORLD CLASS ROOFLIGHTS

Roof Maker Ltd
1 Pinfold Road , Thurmaston
Leicester, LE4 8AS
Tel: 0116 269 6297
Fax: 0116 269 6291
Email: sales@roof-maker.co.uk

Title: DOUBLE GLAZED FIXED FLAT ROOFLIGHT - TYPICAL FITTING GUIDELINES - WARM DECK ROOF CONSTRUCTION

THIS DRAWING IS FOR REFERENCE ONLY. PLEASE REPORTANY DISCREPANCIES TO THE DESIGNER BEFORE ANY WORKSCOMMENCE. ALL DIMENSIONS ARE IN mm. ALL DIMENSIONS TO BE CHECKED ON SITE BEFORE ANY WORKS COMMENCE.

Date: 01/09/2020

Drawn: CS

Checked: WW

Scale: Approx. 1:3 @A4